_			

PLAN REVIEW CONDITIONS

February 12, 2020

SCHARHAG ARCHITECTS 6247 BROOKSIDE BLVD STE 204 KANSAS CITY, MO 64113

Permit No: PRCOM20200280

Project Title: LAKEWOOD COMMERCIAL - BUILDING #1 SHELL

Project Address: XXXX NE LAKEWOOD WAY

Parcel Number:

Location: EXECUTIVE LAKES CENTER LOTS 11B & 11C---LOT 11C

Type of Work: NEW SHELL BUILDING

Occupancy Group:

Description: NEW SHELL BUILDING FOR FUTURE TENANTS

The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please contact the appropriate department regarding clarification of comments.

Development Services Department (816) 969-1200 Fire Department (816) 969-1300

Building Plan Review Reviewed By: Joe Frogge Pending

Fire Plan Review Reviewed By: Michael Weissenbach Approved with Conditions

1. 2018 IFC 906.5- Conspicuous location. Portable fire extinguishers shall be located in conspicuous locations where they will be readily accessible and immediately available for use. These locations shall be along normal paths of travel, unless the fire code official determines that the hazard posed indicates the need for placement away from normal paths of travel.

(Verified At Inspection)

Provide one 2A10BC Fire Extinguisher in each space.

The approval of plans and specifications does not permit the violation of any section of the Building Codes or other City Ordinances or State Law.

The review conducted by the City of Lee's Summit Development Services Department shall not be construed as a structural review of the project.