

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20192670
Address: 920 NW PRYOR RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rough Framing Inspection - Commercial	John Borns	Failed	Wednesday, February 12, 2020

Partial Correction:

1 Misc

PERIMETER WALLS:

ANCHORAGE OF EXTERIOR WALL SILL PLATE APPROVED. NO OTHER ISSUES ON EXTERIOR WALL FRAMING OR EXTERIOR SHEATHING.

Corrective Action Required:

2 Misc

ROOF FRAMING: **WEB BRACING NOT INSTALLED PER TRUSS MANUFACTURER DRAWINGS.**

Comments: