

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20192839
Address: 200 NW CARSON DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Michael Harkins	Failed	Wednesday, February 12, 2020

Corrective Action Required:

1	Misc	Tighten anchor bolt rear bedroom basement - Provide nail guard in corner of basement bath dwv - Nail joist hangers LVLs at stairway FB1 & FB2 - Provide solid security blocking basement door -
---	------	--

Comments: