CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20192572

Address: 1980 SE BLUE PKWY, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

In-wall Inspection Khanh Nguyen Failed Wednesday, February

12, 2020

Corrective Action Required:

1 Misc 1ST FL:

NW AREA BOUNDED BY CORRIDORS : -Protect plumbing at bottom wall track

-Complete insulating and supporting all in-wall water lines

-Install blocking for grab bars

3RD FL:

-Rms not ready: 3-100/111/122/124/125/137

-Fb floor penetrations

-Support and insulatre in-wall water lines

Comments: