

Inspection Summary

Permit #: PRSITE20191266, Development - Site
LEE'S SUMMIT MEDICAL CENTER - HCA MEDICAL OFFICE BUILDING
Address: 1980 SE BLUE PKWY, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

| Inspection: | Inspector: | Outcome: | Date: |
|------------------------|-------------------|-----------------|-----------------------------------|
| DE - Fire Line - Flush | Steve Robbins | Passed | Thursday, February 13, 2020 |

Informational

1 The fire line was flushed for 30-35 minutes at a high velocity. Steve Robbins 02/13/2020 11:54 AM

Comments: