

PLANS REVIEW CONDITIONS

Permit No:	PRCOM20192670	Date:	February 14, 2020
Project Title:	STREETS OF WEST PRYOR LOT 10	Applicant:	
Location:			
	920 NW PRYOR RD, LEES SUMMIT, MO 64081		PALMER ELECTRIC CO
Type of Work:			6600 ROYAL ST, BLDG B
Occupancy Group:	MIX		PLEASANT VALLEY, MO 64068
Description:	NEW SHELL FOR FUTURE	Primary:	(816) 479-2587
	RESTAURANT AND MERCANTILE OCCUPANTS		
	FOUNDATION PERMIT - PRCOM20193203		
Construction Type:	Type VB (Unprotected)		
Map Page:	194D		

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Alarm Plan Review

Reviewed By: Michael Weissenbach

Released for Construction

1. 2018 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

(Informational Purposes)

Call (816)969-1300 to schedule an alarm test.

2. (Informational Purposes)

Provide one horn/strobe in each unoccupied space until tenant finish is submitted. Updated drawings have been submitted to show location.

Alarm Plan Review

Reviewed By: Michael Weissenbach

Released for Construction

1. 2018 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

(Informational Purposes)

Call (816)969-1300 to schedule alarm testing.

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.

