

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20192761
Address: 4704 NE SARATOGA CT, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Michael Harkins	Passed	Friday, February 14, 2020

Informational:

1 Misc

FRAMING:

-Install double joist at stair floor opening

**Code requires double header joist for floor frame opening. You can get the engineer to address this. In case the engineer also requires the double header joist, then you will have to redo the gas piping and retest

DOUBLE JOIST INSTALLED GAS METER INSTALLED NO GAUGE FOR TEST 2/14/20
13:18

Comments: