

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20192480
Address: 1515 SW ARBOR FALLS DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Michael Harkins	Not Ready	Friday, February 14, 2020

Corrective Action Required:

1	Misc	Provide boca plate dwv basement by furnace - Provide fire block separation between stud and foundation wall every 10' minimum per code Provide anchor bolt steel column near sump
---	------	--

Comments: