

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20200266
Address: 829 SW LEMANS LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---|-----------------|----------|---------------------------|
| Final Building Inspection - Commercial | Michael Harkins | Failed | Friday, February 14, 2020 |

Corrective Action Required:

1 Misc

SEE ABOVE CEILING INSPECTION-
FIRE TO APPROVE AT NEXT INSPECTION.

ADD FIRE EXSTINGUISHER PER FD.
COMPLETE ABOVE CEILING

NOTE- WALL AND ELECTRCIAL INSTALLED BEFORE PERMIT WAS ISSUED. NO
INSPECTION OF WALL.

Comments: