

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20183479
Address: 1450 SE BROADWAY DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Mark Harding	Failed	Friday, February 14, 2020

Corrective Action Required:

1	Misc	- INSTALL GRAB BARS AND BATHROOM EQUIPMENT PER ICC ANSI A117.1 , VERTICAL GRAB BAR, TOILET PAPER DISPENSER. - PROTECT NM UNDER MICROWAVE -INSTALL SPARK RINGS AT BATHROOM WALL -SECURE AND SUPPORT PEX WATER PIPE ON 2ND FLOOR AT EXTERIOR WALL AND WATER HEATER. -INSTALL PROTECTION BOOT AROUND PLUMBING UNDER SINK. CHANGE ADDRESS TO BE VISIBLE FROM THE STREET. CONTRASTING COLORS SEE COMMENTS FROM PLANNING, WATER, AND FIRE, SITE ENGINEERING BEFORE TCO CAN BE ISSUED.
---	------	-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

Comments: