

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20182604
Address: 837 NW DONOVAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	John Borns	Partial	Monday, February 17, 2020

Partial Correction:

1 Misc

OK TO COVER WHEN READY CEILING & COMMON /CORRIDOR WALL RATED ASSEMBLIES:

**CENTER SECTION / CLUBHOUSE:
HIGH CEILINGS: ONE LAYER TYPE "C"
10' CEILINGS: ONE LAYER TYPE "X";**

Comments: