CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 **DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRSITE20193328 Address: 920 NW PRYOR RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:		Inspector:	Outcome:	Date:	
DE - Water Line - Construction Inspection		Joe Starlin	Partial	Tuesday, February 11, 2020	
Informational:					
1	Misc	-	ve installed approximately rty fives. They are now back		
Informational:					
2	Misc	30ft. They have approximation	the fire line ran out of the b ately 40ft of waterline insta wenty feet of DIP. They have	lled and are getting	
Informational:					
3	Misc	1-3-2020 9:22am They hav with the DIP pipe.	e installed approximately 4	Oft of waterline. Along	
Informational:					
4	Misc		e a total of 80ft installed an is in place and they are layiı	-	
Informational:					
5	Misc	•	ed approximately 60ft of w ey will be pouring thrust blo	-	
Informational:					
6	Misc	They will be pouring thrus and plenty of rock. They a	installing there last stick of st blocks at 12 noon. They ha re backfilling and using trac ocks and will backfill tomor	ave tracer wire in place er tape. 2:17pm They	

Informati	ional:			
7	Misc	1-14-20 10:20am With the water line complete at 9am we started flushing out the chlorine. 11:30am They have flushed the chlorine out and we will pull samples tomorrow.		
Informational:				
8	Misc	All samples pulled have passed.		

Comments: