

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSITE20193328
Address: 920 NW PRYOR RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
DE - Water Line - Hydrostatic Test	Joe Starlin	Passed	Thursday, January 09, 2020

Informational:	
1 Misc	1-9-20 10:41am The line is under pressure at 200 and has held for 1 hour.
Informational:	
2 Misc	1-9-20 10:41am The line is under pressure at 200 and has held for 1 hour. The waterline has held for over 2 hours at 200 psi.

Comments: