

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20191610
Address: 1507 SW ARBOR FALLS DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Michael Harkins	Failed	Tuesday, February 18, 2020

Corrective Action Required:

1	Misc	-Adjust water meter well to match final grade. _ provide deck pier inspection covered deck _ provide final grade & sod _ provide (2) 3" screws each exterior hinge & strike plate _ provide (3) GFCI receptacles garage 3 car garage _ provide GFCI protection dishwasher & washing machine _ provide city stamped plans check deck beam post attachment _ provide faucets & drains all bathrooms _ seal top of meter can , AC disconnect, low volt penetrations
---	------	--

Comments: