

**CITY OF LEE'S SUMMIT**  
**Development Services Department**  
**220 SE Green Street**  
**Lee's Summit, MO 64063**  
**(816) 969-1200      FAX (816) 969-1201**

# **Temporary**

## **Certificate of Occupancy**

---

**Permit #:**                **PRRES20192146**  
**Address:**              **2516 SW RIVER TRAIL RD, LEES SUMMIT, MO 64082**  
**Inspected On:**        **Tuesday, February 18, 2020**  
**Inspected By:**        **Patrick Schonfeldt**  
**Expiration Date:**    **4/20/2020 12:00:00 AM**

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Patrick Schonfeldt	Temporary C of O	Tuesday, February 18, 2020

**Corrective Action Required:**

- |   |      |   |
|---|------|---|
| 1 | Misc | - Complete final grade<br>- Place sod<br>- Place splash blocks at all downspout and sump pump discharge locations. Minimum distance 3' from foundation. |
|---|------|---|