

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20192522
Address: 2911 SW ARBOR TREE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Michael Harkins	Failed	Tuesday, February 18, 2020

Corrective Action Required:

1	Misc	Provide solid security blocking patio door - Address double 2 x 10 above egress window - Provide joist hanger 2 x 10 egress window/garage - Secure bath exhaust vents with metallic tape - Seal exterior penetration pantry (low volt)
---	------	--

Comments: