

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRCOM20192572  
Address: 1980 SE BLUE PKWY, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>In-wall Inspection</b>	Mark Harding	Partial	Tuesday, February 18, 2020

Corrective Action Required:

1	Misc	1ST FL: NW AREA BOUNDED BY CORRIDORS : -Protect plumbing at bottom wall track  -Install blocking for grab bars  3RD FL: -Rms not ready: 3-100/111/122/124/125/137
---	------	--

**Comments:**