

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20173051
Address: 1980 SE BLUE PKWY, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	Mark Harding	Partial	Tuesday, February 18, 2020

Partial Correction:

1 Misc

ELEVATOR SHAFT:

1ST FL: north wall ok for 5/8" gb at restroom only; other walls need screws at max 12" oc and fire-caulking

2ND FL: elevator/mechanical shaft wall ok; east&west wall ok for 5/8" gb

3RD FL: elevator/mechanical shaft wall ok; east&west wall ok for 5/8" gb

ELEVATOR MECHANICAL SHAFT:

2ND FL: 1-hr lid ok;

3RD FL:

MID-BUILDING MECHANICAL SHAFT:

2ND FL: 1-hr lid ok

3RD FL:

Comments: