CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20192706

Address: 940 NW PRYOR RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

Concrete Walls and Columns John Borns Partial Tuesday, February 18,

Inspection 2020

Partial Correction:

1 Misc OK TO POUR WHEN READY C.I.P. WALL AT:

12/H.5 TO I/12 TO I/10; **E.2/5 TO F.3/5**;

ENSURE KEYWAY AND WATERSTOP ARE CLEAR AND CLEAN PRIOR TO

BUTTONING-UP FORMS.

Partial Correction:

2 Misc OK TO POUR COLUMNS INSIDE BUILDING AT: 1/F;

Comments: