

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20193014
Address: 3005 SW ARBOR TREE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Michael Harkins	Failed	Wednesday, February 19, 2020

Corrective Action Required:

1	Misc	Provide fire blocking stair landing- Provide 2 anchor bolts steel column garage- Seal pan offs in joist - Install fireplace - Provide 800# hold down device EC#2 at front door per plan - Provide strap top plate master bath -
---	------	--

Comments: