

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSITE20192599
Address: 920 NE DEERBROOK ST, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|--|--------------|----------|------------------------------|
| DE - Water Line - Construction Inspection | John Jackson | Passed | Wednesday, February 19, 2020 |

Informational:

| | | |
|---|------|--|
| 1 | Misc | Water main tie in 12"X6" Tee with two 12" sleeves and 6" valve assembly. Night time tie in started at 1:30am Wednesday February, 19. Water main back in service @ 3:30 am, Line was flushed. |
|---|------|--|

Comments: