

Inspection Summary

Permit #: PRSITE20183936, Development - Site
Higdon Construction
Address: 1450 SE BROADWAY DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
DE - Sanitary Sewer Construction Inspection	Steve Robbins	Passed	Wednesday, February 19, 2020
DE - Grading/Excavation/Fill Inspection	Steve Robbins	Partial	Wednesday, February 19, 2020
Informational			
1	Final grade has not been completed, detention basin has been done. They are still working on installing sprinkler system and then will install sod.		
DE - Curb - Proof Roll	Steve Robbins	Passed	Wednesday, February 19, 2020
DE - Storm - Material Verification	Steve Robbins	Passed	Wednesday, February 19, 2020
DE - Storm - Pipe	Steve Robbins	Passed	Wednesday, February 19, 2020
DE - Storm - Inlets Clean	Steve Robbins	Passed	Wednesday,

February 19,
2020

DE - Storm - Outlet Structure	Steve Robbins	Passed	Wednesday, February 19, 2020
DE - Storm - Rip Rap	Steve Robbins	Partial	Wednesday, February 19, 2020

Corrective Action Required

- 1 All the rip-rap has been installed, the rip-rap by the flared end section in the detention basin needs to be cleaned out and possibly have a little more rip-rap installed.

Comments:
