



**PLANS REVIEW CONDITIONS**

Permit No: PRCOM20191614	Date: February 20, 2020
Project Title: THE PRINCETON	Applicant:
Location: 1701 SE OLDHAM PKWY, LEES SUMMIT, MO 64081	ENERGIZE ELECTRONICS INC
Type of Work:	P O BOX 815
Occupancy Group: R-4	BLUE SPRINGS, MO 64013
Description: SENIOR LIVING APARTMENTS WITH INDEPENDENT LIVING, ASSISTED LIVING, AND MEMORY CARE - INCLUDES POOL AND AMENITIES	Primary: (816) 220-0665

Foundation permit: PRCOM20193058  
Construction Type: Type VA (1 hour)  
Map Page: 196K

**Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.**

**Alarm Plan Review                                      Reviewed By: Michael Weissenbach                                      Released for Construction**

1. 2018 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

(Informational Purposes)

Call (816)969-1300 to schedule alarm testing.

2. (Informational Purposes)

Update records showing 2018 I-Series and NFPA 2016

**The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.**