

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20183215
Address: 1420 NE DOUGLAS ST, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underground Electrical Inspection - Commercial	John Borns	Partial	Thursday, February 20, 2020

Partial Correction:

1 Misc

OK TO COVER WHEN READY **SEVEN 3" SECONDARY SERVICE CONDUITS FROM
TRANSFORMER LOCATION TO ~30' FROM BUILDING ENTRY.**

Comments: