

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20192670
Address: 920 NW PRYOR RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	John Borns	Partial	Friday, February 21, 2020

Partial Correction:

1 Misc

OK TO COVER WHEN READY COMPONENTS OF RATED ASSEMBLIES AT:
**WALL ON (3) SOUTH FACE ONE LAYER 5/8" TYPE X GWB OK TO TAPE, MUD
AND FIRESTOP; WALL ON (5) SOUTH FACE ONE LAYER 5/8" TYPE X GWB OK TO
TAPE, MUD AND FIRESTOP;**

Comments: