

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20192670
Address: 920 NW PRYOR RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	John Borns	Partial	Friday, February 21, 2020

Partial Correction:
1 Misc

OK TO CLOSE WOOD-FRAMED WALLS WHEN READY AT:
**WALL ON (3) AND WEST WALL OF CENTER SPACE AFTER PENETRATIONS OF
TOP PLATE ARE FIREBLOCKED;**

Comments: