

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20191159  
Address: 120 SW BLUE PKWY, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Concrete Walls and Columns Inspection</b>	John Borns	Partial	Friday, February 21, 2020

Partial Correction:

1 Misc

OK TO CLOSE FORMS AND POUR WHEN READY C.I.P. WALLS: THREE CAISSON CHAMBER DIVIDER WALLS; WEST POOL WALL FROM NORTH ALONG WIDTH OF SURGE TANK; EAST POOL WALL NORTH 25'; REAR WALL OF CAISSON CHAMBERS; BUILDING FOUNDATION WALLS EAST OF WEST POOL WALL; BUILDING FOUNDATION WALLS EXCEPT AT PUMP PIT & SW 15' OF FILTRATION; FRONT WALL OF CAISSONS; REMAINDER OF EAST POOL WALL INCLUDING BONDING FOR LADDER & FIVE NICHE LIGHT SHELLS; **WEST POOL WALL INCLUDING BONDING FOR LADDER & FIVE NICHE LIGHT SHELLS;**

**\*\*SURGE TANK WALLS-OK. 2 ACCESS OPENINGS WILL BE CLOSED. PICTURE VERIFICATION WILL BE PROVIDED FOR NEXT INSPECTION**

**Comments:**