

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRCOM20182607  
Address: 829 NW DONOVAN RD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Rated Assembly Inspection</b>	John Borns	Partial	Friday, February 21, 2020

Partial Correction:

1 Misc

OK TO COVER WHEN READY 5/8" MOLD-RESISTANT FIRECODE X GWB AT STAIRWELL WALLS INSIDE FACE AND SPACES BETWEEN JOISTS AT BACKSIDE:

NORTH STAIRWELL #2:  
BASEMENT LEVEL: 1ST LAYER; 2ND LAYER;  
1ST FLOOR: 1ST LAYER; 2ND LAYER;  
2ND FLOOR: 1ST LAYER; 2ND LAYER;  
3RD FLOOR: 1ST LAYER; 2ND LAYER;  
4TH FLOOR:

SOUTH STAIRWELL #1:  
1ST FLOOR: 1ST LAYER; 2ND LAYER;  
2ND FLOOR: 1ST LAYER; 2ND LAYER;  
3RD FLOOR: 1ST LAYER; 2ND LAYER;  
4TH FLOOR:

NOTE: FIRESTOPPING WHERE PVC PIPE INTERRUPTS GWB IS SUBJECT TO APPROVAL WHEN COMPLETED. USE ONLY LISTED FIRE CAULK.

Partial Correction:

2 Misc

OK TO COVER WHEN READY 5/8" MOLD-RESISTANT FIRECODE X GWB AT

ELEVATOR SHAFT WALLS INSIDE FACE AND SPACES BETWEEN JOISTS AT BACKSIDE:

BASEMENT LEVEL:

1ST FLOOR: 1ST LAYER; 2ND LAYER;

2ND FLOOR: 1ST LAYER; 2ND LAYER;

3RD FLOOR: 1ST LAYER; 2ND LAYER;

4TH FLOOR:

Partial Correction:

3 THE FOLLOWING  
AREAS ARE  
APPROVED

OK TO COVER 5/8" MOLD-RESISTENT TYPE "X" GWB AT TUB/SHOWER WALLS:  
ONE LAYER AT 4TH FLOOR, 3RD FLR, 2ND FLR, 1ST FLR; TWO LAYERS WHERE  
REQUIRED AT SHEAR WALLS, TUBS/SHOWERS ADJACENT TO STAIRWELLS,  
ELEVATOR, CORRIDORS - ALL FLOORS

**BASEMENT STORAGE ROOMS & ELEVATOR MACHINE ROOM WALLS 1 LAYER;**

**Comments:**