CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20191159

Address: 120 SW BLUE PKWY, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

Underground Plumbing John Borns Passed Friday, February 21,

Inspection - Commercial 2020

Comments: OK TO COVER WHEN READY:

- 2" COPPER WATER LINE FROM 5' OUTSIDE B/L TO BUILDING ENTRY AT SURGE TANK
- 6" PVC DRAIN LINE FROM 5' OUTSIDE B/L TO BUILDING ENTRY AT NW
- 4" PVC DRAIN LINE FROM 5' OUTSIDE B/L TO BUILDING ENTRY AT NE
- 3" COPPER WATER LINE FROM 5' OUTSIDE B/L TO BUILDING ENTRY AT NE