

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20192670
Address: 920 NW PRYOR RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	John Borns	Partial	Monday, February 24, 2020

Partial Correction:

1 Misc

OK TO COVER WHEN READY COMPONENTS OF RATED ASSEMBLIES AT:
WALL ON (3) SOUTH FACE ONE LAYER 5/8" TYPE X GWB; **2ND LAYER OK TO TAPE, MUD AND FIRESTOP AFTER SCREWS ARE ADDED AS POINTED OUT;**

WALL ON (5) SOUTH FACE ONE LAYER 5/8" TYPE X GWB;

Comments: