

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20192670
Address: 920 NW PRYOR RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underground Plumbing Inspection - Commercial	John Borns	Partial	Monday, February 24, 2020

Corrective Action Required:

1	Misc	2,000 GAL. INTERCEPTOR NOT PIPED PER APPROVED DRAWING.
AT RE-INSPECTION OPEN ALL LIDS FOR INSPECTION OF TANK INTERIORS.		

Comments: