

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20193192
Address: 1820 SW MERRYMAN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Plumbing Inspection - Residential	Patrick Schonfeldt	Failed	Monday, February 24, 2020

Corrective Action Required:

1	Misc	- If running interior drain tile diagonal across it needs to reach opposite diagonal corner footing. Interior drain tile currently several feet short of opposite foundation footing curled back at pier pad.
---	------	---

Comments: