

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20193042
Address: 2917 NW AUDUBON LN, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Michael Harkins	Failed	Tuesday, February 25, 2020

Corrective Action Required:

1	Misc	Provide fire blocking at sliding glass door great room- Fur out garage to allow for insulation pantry- Install missing windows- Seal off front porch from office - Provide flood light back yard-
---	------	---

Comments: