## CITY OF LEE'S SUMMIT **Development Services Department** 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

## **DEVSERVICES.CITYOFLS.NET**

## **Inspection Summary**

Permit #:

PRSITE20183804

Address:

1706 NW OBRIEN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:

Inspector:

Outcome:

Date:

DE - Fire Line - Hydrostatic Test Ronald Paynter

Passed

Tuesday, May 07, 2019

Informational:

1

Misc

Fire line passed hydrostatic test of 200 PSI for 2 hrs.

Comments: