

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20200191

Address: 1237 NE DOUGLAS ST, Unit:201, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	Mark Harding	Failed	Wednesday, February 26, 2020

Corrective Action Required:

1	Misc	-FIRE STOP ALL FLOOR CEILING PENETRATIONS. -PLUMBING FOR FLOOR DRAIN - BACK TO BACK FITTINGS MAKING A "S" TRAP. PROVIDE 2 PIPE SIZE DIAMETERS FROM TRAP WIER TO DRAIN. OK TO INSULATE
---	------	--

Comments: