

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20172541

Address: 253 NW KESSLER DR, Unit:MAINT, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	Michael Harkins	Failed	Wednesday, February 26, 2020

Corrective Action Required:

1	Misc	Provide city stamped truss package- Install windows check flashing on wood sills- Provide anchor bolts perimeter of maintenance building & within 12" of plate breaks
---	------	---

Comments: