

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20182604  
Address: 837 NW DONOVAN RD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Rated Assembly Inspection</b>	Mark Harding	Partial	Wednesday, February 26, 2020

Partial Correction:

1	Misc	OK TO COVER WHEN READY RATED CEILING & WALL ASSEMBLIES: RIGHT WING 1ST FLOOR COMPLETE
---	------	--

Corrective Action Required:

2	ELEVATOR 1	RIGH WING ELEVATOR SHAFT MACHANICAL ROOM; 1ST FLOOR CEILING-3RD LAYER AND RC CHANNEL;
---	------------	---

**Comments:**