

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20192817
Address: 121 NW MACKENZIE DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Michael Harkins	Failed	Wednesday, February 26, 2020

Corrective Action Required:

1 Misc

Corrective Action Required:

2 Misc

No footing inspection on record -
No pier inspection on record -
Provide min one 5/8 anchor bolt per plan PFH portal frame garage -
Address rafters landing on multiple blocks throughout house -
Provide insulation at cantilever living room complete soffit & trim horizontal flashing if required -
Provide shield master shower rain head pex within 12" of can light -
Provide solid security blocking patio door -

Comments: