

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20192035
Address: 1105 NE GOSHEN CT, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Khanh Nguyen	Failed	Thursday, February 27, 2020

Corrective Action Required:

1	Misc	-THE RIDGE IS NOT STRAPPED DOWN TO THE LVL BEAM BELOW AS PER ENGINEER LETTER DATED FEB-26
---	------	---

Comments: