

DEVELOPMENT SERVICES

Building Permit - Commercial	Permit No: PRCOM20193544
Project Title: DCI - LEE'S SUMMIT	Date Issued: February 27, 2020
Work Desc: NEW COMMERCIAL	
Project Address:	Permit Holder:
2001 NW SHAMROCK AVE, LEES SUMMIT, MO 64081	AXIOM NORTHWEST CONSTRUCTION INC
	2232 BROADWAY STE 101
Legal Description: WEST VILLAGE COMMERCIAL	EVERETT, WA 98201
DEVELOPMENT LOTS 1-3 LOT 2	
Parcel No: 6224099040000000	
County: IACKSON	

Activities Included for this Project:

zNew Commercial, License Tax, Above Ceiling Permit, Alarm Permit, Electrical Permit Commercial, Electrical Service Permit Commercial, Foundation Permit Commercial, Gas Permit Commercial, Gas Service Permit Commercial, In-Wall Inspection Permit, Mechanical Permit Commercial, Plumbing Permit Commercial, Sprinkler Permit, Fire Rated Assemblies Permit,

Construction Type: Type VB (Unprotected)	Occupancy: BUSINESS Valuation: \$3,500,000	=
Residential Area:		
Commercial Area	1	0442 sq. ft.
Issued By:		Pate: Feb 27, 2020

THIS PERMIT IS ISSUED IN RELIANCE UPON INFORMATION SUBMITED BY THE APPLICANT. THE BUILDING OFFICIAL MAY SUSPEND OR REVOKE WHENEVER THE PERMIT IS ISSUED IN ERROR, OR ON THE BASIS OF INCORRECT INFORMATION SUPPLIED, OR IN VIOLATION OF ANY ADOPTED CODE, CITY ORDINANCE OR REGULATIONS.

NOTICE: THE DISPOSAL OF DEMOLITION WASTE IS REGULATED BY THE DEPARTMENT OF NATURAL RESOURCES UNDER CHAPTER 260 RSMO. SUCH WASTE, IN TYPES AND QUANTITIES ESTABLISHED BY THE DEPARTMENT, SHALL BE TAKEN TO A DEMOLITION LANDFILL OR A SANITARY LANDFILL FOR DISPOSAL.

CONDITIONS

One or more divisions have conditions that have not been addressed during the review period. The outstanding conditions provided below shall be met as indicated during the construction period.

Fire Plan	Review
-----------	--------

- 2018 IFC 907.1.1- Construction documents. Construction documents for fire alarm systems shall be submitted for review and approval prior to system installation. Construction documents shall include, but not be limited to, all of the following: 1. .A floor plan which indicates the use of all rooms. 2. Locations of alarm-initiating and notification appliances.
- 3. Alarm control and trouble signaling equipment. 4. Annunciation. 5. Power connection. 6. Battery calculations. 7.

Conductor type and sizes. 8. Voltage drop calculations. 9. Manufacturers, model numbers and listing information for equipment, devices and materials. 10. Details of ceiling height and construction. 11. The interface of fire safety control functions.

(Action Required)

Provide three sets of PE stamped shop drawings for the fire alarm system.

2 2018 IFC 505.1- Address numbers. New and existing buildings shall have approved address numbers, building numbers or approved building identification placed in a position that is plainly legible and visible from the street or road fronting the property. These numbers shall contrast with their background. In Multi-tenant commercial building where tenants have multiple entrances located on different sides of the building, each door shall be addressed. Address numbers shall be Arabic numerals or alphabet letters. Numbers shall be a minimum of 4 inches (102 mm) high with a minimum stroke width of 0.5 inch (12.7 mm).

(Verified At Inspection)

2018 IFC 506.1- Where required. Where access to or within a structure or an area is restricted because of secured openings or where immediate access is necessary for life-saving or fire-fighting purposes, the fire code official is authorized to require a key box to be installed in an approved location. The key box shall be of an approved type and shall contain keys to gain necessary access as required by the fire code official.

(Verified At Inspection)

Order a Knox box from knoxbox.com. Placement to be made by FDC.

2018 IFC 901.2- Construction documents. The fire code official shall have the authority to require construction documents and calculations for all fire protection systems and to require permits be issued for the installation, rehabilitation or modification of any fire protection system. Construction documents for fire protection systems shall be submitted for review and approval prior to system installation.

(Action Required)

Provide three sets of PE stamped shop drawings for the fire sprinkler system.

2018 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

(Informational Purposes)

Call (816)969-1300 to schedule testing.

2018 IFC 1010.1.9 Door operations. Except as specifically permitted by this section, egress doors shall be readily openable from the egress side without the use of a key or special knowledge or effort. (Verified At Inspection)

Building Plan Review

A License Tax application completed by the contractor must be submitted to the City of Lee's Summit, Codes Administration Department, and any applicable License Tax paid prior to issuing a building permit.

Action required: Comment is for informational purposes. 12/23/19 - acknowledged in letter

4 Copies of the engineered truss package were not provided at the time of permit application.

Action required: Provide truss package or request deferral. 12/23/19 - deferred per request

Licensed Contractors		
Signature of Applicant:		
Applicant:	Date:	
Print name:	Company Name:	