CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20200392

Address: 616 SW 3RD ST, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

Final Building Inspection - John Borns Passed Thursday, February 27,

Commercial 2020

Comments: ENSURE ELECTRICAL PANEL SCHEDULES ARE COMPLETE, CURRENT, ACCURATE, AND LEGIBLE. RECOMMEND CAPS/PLUGS AT ALL UNUSED WATER LINES RATHER THAN DEPENDING ON VALVES ONLY. THEN OK FOR USE & OCCUPANCY.