

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20200191
Address: 1237 NE DOUGLAS ST, Unit:201, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	John Borns	Passed	Thursday, February 27, 2020

Comments: OK TO COVER WHEN READY WOOD WALL FRAMING + ENCLOSED SYSTEMS ROUGH-IN.

**ISSUE REMAINING FOR LATER INSPECTION BELOW FLOOR:
PLUMBING FOR FLOOR DRAIN - BACK TO BACK FITTINGS MAKING AN "S" TRAP. PROVIDE 2 PIPE SIZE
DIAMETERS FROM TRAP WIER TO DRAIN.**