

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRSUBD20190654

Address: 2030 NW OBRIEN RD, LEES SUMMIT, MO 640812020 NW OBRIEN RD, LEES SUMMIT, MO 64081500  
NW PRYOR RD, LEES SUMMIT, MO 64081450 NW PRYOR RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>DE - Water Line - Abandonment</b>	Ronald Paynter	Partial	Thursday, February 27, 2020

Informational:

1 Misc

Darren's crew removed the old fire hydrant, service line and meter well that went to the vacant office off Pryor. I contacted Brad Woodford at Water about the meter well lid and fire hydrant. He said they would be out on Friday to reclaim the materials. RP 2-27-20

**Comments:**