

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20182387  
Address: 2023 NW SHAMROCK AVE, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Rated Assembly Inspection</b>	Mark Harding	Partial	Thursday, February 27, 2020

Corrective Action Required:	
1 THE FOLLOWING AREAS ARE APPROVED	1HOUR SEPARATION WALL BETWEEN SLEEPING ROOMS- TOP OUT TO ROOF DECK DOWN TO CEILING HEIGHT. OK TO INSULATE AND ROCK BOTH SIDES DOWN TO CEILING HEIGHTS.  ONE HAS BEEN INSTALLED TO THIS POINT

**Comments:**