

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20171395
Address: 110 SE 3RD ST, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	John Borns	Failed	Thursday, February 27, 2020

Corrective Action Required:

1	Misc	RECEPTACLES AT POINT OF SERVICE: - ONE AT CENTER NOT SOLID TO BOX - ONE AT EAST END SHOWS FAULTY GROUND
---	------	---

Corrective Action Required:

2	Misc	INSTALL RESTROOM GRAB BARS PER IBC
---	------	------------------------------------

Corrective Action Required:

3	Misc	INSTALL RESTROOM SIGN PER CODE
---	------	--------------------------------

Corrective Action Required:

5	Misc	NEC 408.4: LABELING OF ELECTRICAL CIRCUIT POSITIONS AT PANEL(S): EACH BREAKER POSITION MUST BE LABELED. MUST BE LEGIBLE, SPECIFIC. IF PANEL SCHEDULE IS USED NUMBER POSITIONS ON PANEL FRONT PER SCHEDULE. NO DITTO MARKS OR CONTINUATION SYMBOLS EXCEPT @ MULTIPLE POLE BREAKERS. LABEL UNUSED BREAKERS "SPARE".
---	------	---

Comments: