

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20192808
Address: 152 NW CARSON DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Michael Harkins	Failed	Friday, February 28, 2020

Corrective Action Required:

1	Misc	Provide PFH portal frame per plan Double bottom plate - min (1) 5/8 anchor bolt installed per R403.1.6 - Strap Hold downs, header to jack strap, nailing pattern OK
---	------	--

Comments: