

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20191887
Address: 1537 SW ARBOR FALLS DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Patrick Schonfeldt	Failed	Friday, February 28, 2020

Corrective Action Required:

- | | | |
|---|------|---|
| 1 | Misc | <ul style="list-style-type: none">- Submit as graded plot plan for review- Door to garage must be self closing- Access required to jacuzzi tub motor- Breaker lockout required for hardwired cooktop/hood- Main water line in basement, anti siphon required with set screw sheared off- AFCI protection required at all locations per 2017 NEC 210.12- Dishwasher GFCI protection required NEC 210.8- Seal all exterior penetrations- Complete final grade and place sod- Place splashblocks at all downspout and sump pump discharge locations, minimum distance to foundation 36" |
|---|------|---|

Comments: