

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20193015
Address: 3001 SW ARBOR TREE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Michael Harkins	Failed	Friday, February 28, 2020

Corrective Action Required:

1	Misc	Maintain silt fence. Provide bond gas line. Provide hanger HGUS28-2 truss C-1 per truss layout. Provide PFH portal frame garage per plan Min (1) 5/8 anchor bolt , double bottom plate.
---	------	---

Corrective Action Required:

2	Misc	Maintain silt fence. Provide bond gas line. Provide hanger HGUS28-2 truss C-1 per truss layout. Provide PFH portal frame garage per plan Min (1) 5/8 anchor bolt , double bottom plate. Provide pier inspection patio post.
---	------	--

Comments: