

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20191955  
Address: 920 NE DEERBROOK ST, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Foundation Inspection - Commercial</b>	Khanh Nguyen	Partial	Friday, February 28, 2020

Corrective Action Required:

1	Misc	ELEVATOR WALL- LOWER 4' WALL ONLY, FOOTING NOT APPROVED OR INSPECTED.  SW STAIRWAY ENCLOSURE: -SOUTH F. WALL FORM AND REINFORCEMENT INSTALLED PER PLAN. WALL TIED TO FOUNDATION WALL ALREADY INSPECTED AND OK TO POUR BY PSI.
---	------	--

**Comments:**