

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20191770

Address: 2861 NE INDEPENDENCE AVE, Unit:101, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	Khanh Nguyen	Partial	Friday, February 28, 2020

Partial Correction:

1 Misc

Above-ceiling approved for following areas:

All areas ok, except sterilizer rm 1159 above the added sink where the hole in the 1-hr wall needs to be patched

**Ceiling-mounted operation light circuits must meet NEC517.13

Comments: